

Lead in Water Test Results Summary: Bunker Hill

Notes:

- The lead in water **Action Level is 15 parts per billion (ppb)**.
Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.
- A "ND" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **greater than or equal to the Action Level of 15 ppb** are highlighted in red and precede an "Action Req." (Action Required) value in the "Initial Level" or "Final Level" column.
- Test results **from 12 ppb to 14.99 ppb (near the Action Level)** are highlighted in orange and precede a "High" value in the "Initial Level" or "Final Level" column.
- Test results **from 5 ppb to 11.99 ppb** are highlighted in yellow and precede a "Moderate" value in the "Initial Level" or "Final Level" column.
- Test results **less than 5 ppb** are not highlighted and precede a "Low" value in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
Room 1 Classroom Faucet	19650700-001CF25	6/13/2025	3.09	Low	[enter date]	[enter result]	[autofill]
Room 1 Drinking Fountain	19650700-002DW25	6/13/2025	1.15	Low			
Room 1 Bathroom Faucet	19650700-003BF25	6/13/2025	1.46	Low			
Room 2 Drinking Fountain	19650700-004DW25	6/13/2025	1.64	Low			
Room 2 Classroom Faucet	19650700-005CF25	6/13/2025	0.941	Low			
Room 2 bathroom faucet	19650700-006BF25	6/13/2025	1.07	Low			
Room 3 Drinking Fountain	19650700-007DW25	6/13/2025	3.01	Low			
Room 3 bathroom faucet	19650700-008BF25	6/13/2025	0.803	Low			
Room 4 classroom faucet	19650700-009CF25	6/13/2025	1.17	Low			
Room 4 drinking fountain	19650700-010DW25	6/13/2025	ND	Non-Detect			
Room 4 bathroom faucet	19650700-011BF25	6/13/2025	0.867	Low			
Room 5 Classroom Faucet	19650700-012CF25	6/13/2025	7.56	Moderate			
Room 5 drinking fountain	19650700-013DW25	6/13/2025	2.56	Low			
Room 6 Classroom Faucet	19650700-014CF25	6/13/2025	3.18	Low			
Room 6 Drinking Fountain	19650700-015DW25	6/13/2025	6.43	Moderate			
Room 7 classroom faucet	19650700-016CF25	6/13/2025	4.29	Low			
Room 7 drinking fountain	19650700-017DW25	6/13/2025	4	Low			
Room 8 Classroom faucet	19650700-018CF25	6/13/2025	3.77	Low			
Room 8 drinking faucet	19650700-019DW25	6/13/2025	1.99	Low			
Girls Bathrooms across from office Left bathroom faucet	19650700-020BF25	6/13/2025	3.53	Low			
Girls Bathrooms across from office Right bathroom faucet	19650700-021BF25	6/13/2025	4.82	Low			
Boys Bathrooms across from office left bathroom faucet	19650700-022BF25	6/13/2025	6.26	Moderate			
Boys Bathrooms across from office right bathroom faucet	19650700-023BF25	6/13/2025	5.55	Moderate			
Water Bottle fill station outside of main office	19650700-024WB25	6/13/2025	ND	Non-Detect			
Health Room Sink	19650700-025NS25	6/13/2025	1.11	Low			
Health room Bathroom faucet	19650700-026BF25	6/13/2025	1.4	Low			
Staffroom faucet	19650700-027SF25	6/13/2025	1.41	Low			
Girls Bathrooms across from Room 9 bathroom faucet left	19650700-028BF25	6/13/2025	4.11	Low			
Girls Bathrooms across from Room 9 bathroom faucet middle	19650700-029BF25	6/13/2025	6.2	Moderate			
Girls Bathrooms across from Room 9 bathroom faucet right	19650700-030BF25	6/13/2025	4	Low			
Boys Bathrooms across from Room 9 bathroom faucet left	19650700-031BF25	6/13/2025	2.87	Low			
Boys Bathroom across from Room 9 bathroom faucet middle	19650700-032BF25	6/13/2025	1.41	Low			
Boys Bathroom across from Room 9 bathroom faucet right	19650700-033BF25	6/13/2025	3.85	Low			
Room 9 Classroom faucet	19650700-034CF25	6/13/2025	38	Action Req.	7/16/2025	14	High
Room 10 Classroom faucet	19650700-035CF25	6/13/2025	10.2	High			
Room 10 drinking fountain	19650700-036DW25	6/13/2025	12.6	High			
Room 15 Classroom faucet	19650700-037CF25	6/13/2025	3.05	Low			
Room 15 drinking fountain	19650700-038DW25	6/13/2025	3.77	Low			
Room 11 Classroom faucet	19650700-039CF25	6/13/2025	5.94	Moderate			

Room 11 Drinking fountain	19650700-040DW25	6/13/2025	11	High			
Room 14 Classroom faucet	19650700-041CF25	6/13/2025	10.8	High			
Room 14 drinking fountain	19650700-042DW25	6/13/2025	9.37	Moderate			
Room 12 Classroom faucet	19650700-043CF25	6/13/2025	1.91	Low			
Room 13 Classroom Faucet	19650700-044CF25	6/13/2025	4.69	Low			
Room 13 drinking fountain	19650700-045DW25	6/13/2025	33.9	Action Req.	7/16/2025	ND	Non-Detect
Outside drinking fountain	19650700-046DW25	6/13/2025	2.88	Low			
Boys bathroom in Gym bathroom faucet left	19650700-047BF25	6/13/2025	0.702	Low			
Boys bathroom in Gym bathroom faucet middle	19650700-048BF25	6/13/2025	0.638	Low			
Boys bathroom in Gym bathroom faucer right	19650700-049BF25	6/13/2025	ND	Non-Detect			
Girls bathroom in gym bathroom faucet left	19650700-050BF25	6/13/2025	1.32	Low			
Girls bathroom in gym bathroom faucet middle	19650700-051BF25	6/13/2025	ND	Non-Detect			
Girls bathrooom in gym bathroom faucet right	19650700-052BF25	6/13/2025	ND	Non-Detect			
kitchen faucet in gym	19650700-053KF25	6/13/2025	0.752	Low			
Kitchen bathroom faucet	19650700-054BF25	6/13/2025	1.09	Low			
Room 3 classroom faucet	19650700-055CF25	6/13/2025	ND	Non-Detect			
Girls bathroom faucet next to custodial closer left	19650700-056BF25	7/16/2025	ND	Non-Detect			
Girls bathroom faucet next to custodial closet right	19650700-057BF25	7/16/2025	0.757	Low			